



# Certificate of Compliance

## FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

<b>System Designation:</b>	Control Inert Inergen Clean Agent Fire Extinguishing Systems
<b>Design, Installation, Operation, and Maintenance Manual:</b>	Fire Eater Control Inert Ci Manual for UL Listed, FM Approved Extinguishing System, P/N Ci Manual 2014 FM-UL, Rev. 2014-10-26
<b>Flow Calculation Software:</b>	Fire Eater Inergen Management Tool (IMT) flow calculation program Version 2.2.0, utilizing Flow sim engine dated 2014-08-27

*Approval Guide* Listing Category: Fixed Extinguishing Systems, Clean Agent Fire Extinguishing Systems

Fire Eater A/S  
Vølundsvej 17  
3400 Hillerød  
Denmark

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

*Approval Standards*

<i>Class Number</i>	<i>Date</i>
5600	April 2013

FM Approvals Listing Class: 5611

Original Approval Project Identification: 3039375  
Subsequent Revisions: 3048165, 3050976

Approval Granted: May 24, 2013

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

A handwritten signature in dark ink, appearing to read 'J.E. Marquedant', is written over a horizontal line.

21 November 2014

Date

James E. Marquedant  
Manager - Electrical Systems  
FM Approvals  
1151 Boston-Providence Turnpike,  
Norwood MA, 02062 USA



*Member of the FM Global Group*