

File Reference: CSM 07020-03 (FFA)

Issue Date: 11 May 2017

Certificate Number: FFA/FFS/2017/02

Statement of Acceptance

This is to certify that the:

Fixed Fire Fighting System

has met the prescribed requirements under 42B.22

Product Name	INERGEN Fire Extinguishing System.
Manufacturer	Fire Eater Voelundsvej 17 Hilleroed Denmark 3400
Application	<ul style="list-style-type: none">• Fixed gas fire extinguishing system using fire extinguishing agent Inergen stored in cylinders and distributed through pipes and nozzles for machinery spaces and cargo pump rooms.• Accepted as meeting Maritime Rule 42B.22.• Suitable for use on board New Zealand commercial SOLAS and Non-SOLAS as prescribed by the rules.
Conditions	<ul style="list-style-type: none">• The user must be advised of the correct application, limitations and servicing requirements of this product.• To be serviced and used in accordance with the manufacturer's specifications and recommendations.• The quality procedures specified for the manufacture of the fixed fire fighting system are to be maintained.• Issued subject to the EC-Type Examination Certificate (Module B) issued by DNV-GL remaining valid (certificate number MEDB00001WD).
Expiry Date	11 May 2022 Unless suspended or revoked by the Director at any time before that date.



Sharyn Forsyth
General Manager Maritime Standards
(Acting under delegated authority)