



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

System Designation:	Control Inert Inergen Clean Agent Fire Extinguishing Systems	
Design, Installation, Operation, and Maintenance Manual:	Fire Eater Control Inert Ci Manual for UL Listed, FM Approved Extinguishing System, P/N Ci Manual 2019-03 FM-UL, Rev. 2019-02-27	
Flow Calculation Software:	Fire Eater Inergen Management Tool (IMT) flow calculation program Version 2.2.0, utilizing Flow Sim Engine dated 2014-08-27 or Fire Eater Inergen Management Tool (IMT) flow calculation program 3.x.y (where x and y can be any number), utilizing Flow Sim Engine dated 2018-08-02	
Approved Filling Facilities:	Air Products Turanka 94 62700 Brno Czech Republic	Shanghai Leinuo Security Technology Co., Ltd Building 1, No. 919, Xin Kang Road Qing Pu District, Shanghai China

Approval Guide Listing Category: Fixed Extinguishing Systems, Clean Agent Fire Extinguishing Systems

Fire Eater A/S
Vølundsvej 17
3400 Hillerød
Denmark

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

<i>Approval Standards</i>	<i>Date</i>
<i>Class Number</i> 5600	August 2021

FM Approvals Listing Class: 5611

Original Approval Project Identification: 3039375
Subsequent Revisions: 3048165, 3050976, 3055235, PR451963, PR460150

Approval Granted: May 24, 2013

To verify the availability of the Approved product, please refer to www.approvalguide.com



J.E. Marquedant
James E. Marquedant
VP, Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

24 November 2021

Date