

File Reference: CSM 07020-03 (FFA)

Issue Date: 18 January 2023

Certificate Number: FFA/FFS/2023/01

Statement of Acceptance

This is to certify that the:

Fixed Fire Fighting System

has met the prescribed requirements under 42B.22

Product Name INERGEN Fire Extinguishing System.

Manufacturer Fire Eater
Voelundsvej 17
Hilleroed
Denmark 3400

Application

- Fixed gas fire extinguishing system using fire extinguishing agent Inergen stored in cylinders and distributed through pipes and nozzles for machinery spaces and cargo pump rooms.
- Accepted as meeting Maritime Rule 42B.22.
- Suitable for use on board New Zealand commercial SOLAS as prescribed by the rules 40B.17, 40B.18 or 40B.19 as appropriate.

Conditions

- The user must be advised of the correct application, limitations and servicing requirements of this product.
- To be serviced and used in accordance with the manufacturer's specifications and recommendations.
- The quality procedures specified for the manufacture of the fixed fire fighting system are to be maintained. (ISO 9001:2015 and directive 2014/90/EU)
- Issued subject to the EC-Type Examination Certificate (Module B) issued by DNV-GL remaining valid (certificate number MEDB00001WD Revision 1).

Expiry Date 14 November 2026
Unless suspended or revoked by the Director at any time before that date.



Sophie Crosland
Advisor Regulatory Licensing
(Acting under delegated authority)