

QUICK GUIDE to estimate required amount of cylinders in relation to room size

| PCS/M ³ | DIMENSIONS (METERS) | CYLINDERS (80L, 300 BAR) |
|--------------------|-------------------------|--------------------------|
| 50 | H: 2,5 / B: 4 / L:5 | 1 |
| 100 | H: 2.5 / B: 5 / L: 8 | 2 |
| 200 | H: 2.5 / B: 7 / L: 11,5 | 4 |
| 500 | H: 4 / B: 8 / L: 15,5 | 10 |
| 1000 | H: 6 /B: 10 / L: 17 | 20 |
| 2500 | H: 7 / B: 14,5 / L: 25 | 50 |
| 5000 | H: 10 / B: 16,5 / L: 30 | 105 |
| 7500 | H: 10 / B: 19 / L: 39 | 155 |
| 10.000 | H: 10 / B: 22,5 / L: 45 | 210 |

Note:

The number of cylinders depends on the chosen standard, and several factors can influence the outcome, such as temperature.